DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.
dwtltt1@gmail.com

To,

PINELANDS INTERNATIONAL CONVENT SCHOOL
GAGGUBUA , TARN TARAN

No.: DWTLTT/2627/00088 Dated : 19/05/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 406 Dated: 18/05/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 18/05/2026. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Tarn Taran

D/A : Test Report

Authorized Signatory
For, District Water Testing Laboratory
Tarn Taran

DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.
dwtltt1@gmail.com

TC-14756

TEST REPORT


Name & Address of Customer : PINELANDS INTERNATIONAL CONVENT SCHOOL GAGGUBUA , TARN TARAN		Customer Reference No.	No : 406 Dated : 18/05/2026
		Sample Submitted by	Mr. Varinder Singh
		Date of Sample Receipt	18/05/2026
		Analysis Starting Date	18/05/2026
		Analysis completion Date	19/05/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC147562600000179F	Sample Type :	Treated Water
Test Report No.:	DWTLTT/2627/00088	Date of Issue :	19/05/2026
Registration no.:	DWTLTT/REG2627/00173	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	NA / NA
Village :	Adda Gagobua	Habitation :	Adda Gagobua
Block:	Gandiwind	District :	Tarn Taran
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.98@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	294@180°C	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.66@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	240	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	144	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	28.85	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	17.50	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	19.99	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't beused be as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Mr.Mohammad Naushad Alam
Quality Manager

PRFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE.

NO. 743 DATE : 20-5-2026

It is certified that an inspection team headed by **(Sub Divisional Engineer)** from **Water Supply & Sanitation , Sub Division , Tarn Taran.** inspected the Pinelands International Convent School, Gaggubua , Tarn Taran (PB) on **19.05.2026** and found that Pinelands International Convent School, Gaggubua ,Tarn Taran (PB) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school as per the norms prescribed by the Central/ State/ U.T Govt.

The above valid for a period of **18.05.2027**

Signature with Seal: _____

Designation : SUB DIVISIONAL ENGINEER

Pinelands International Convent School,
Gaggubua ,Tarn Taran

Civil Surgeon Office Tarn Taran

No.CSTT/san/...83 Date:- 21/5/2026

To Whom It May Concern

This is to certify that we have inspected **Pinelands International Convent School Gaggobua, Chabhal District Tarn Taran** After inspecting their Toilets, and other rooms, we can certify that their Cleanliness and sanitation is good. Their water is Potable through RO system as per report of Rural Water Supply and Sanitation Department. This certificate is valid for one year from the date of issue. No Health Hazard is seen in the premises of the school.

District Epidemiologist
Tarn Taran

District Epidemiologist
Civil Surgeon Office
Tarn Taran